



Certificate of Compliance

Certificate: 1532518 (LM 90436)

Master Contract: 204236

Project: 1656670

Date Issued: 2005/09/26

Issued to: Kerotest Manufacturing Corporation


5500 Second Ave
Pittsburgh, PA 15207-1861
USA

Attention: Mr. Richard W. Conley


The products listed below are eligible to bear the CSA Mark shown



Issued by:


Nils Holm

Authorized by: Nick Alfano, Operations
Manager



PRODUCTS

CLASS 7615 01 - PLASTIC PIPE - Gas Piping Systems - Pipe and Fittings

Polyethylene (PE) valves ("POLYBALL" tradename), for use in PE gas piping systems (service temperature range: -29°C to 38°C):

· PE2406 full-port ball valves, with spigot ends ("standard" models, without purge outlets): 1-1/4 in SDR-10; 2, 3, 4, 6 in SDR-11; 1-1/4, 2, 3, 4, 6 in SDR-13.5.

APPLICABLE REQUIREMENTS

CSA Standard B137.4-02 - Polyethylene Piping Systems for Gas Services